

# ADDENDUM NO. 1

## US 41 LIFT STATION AND SEWER REPLACEMENT PROJECT

TOWN OF ROCKVILLE, INDIANA  
AMERICAN STRUCTUREPOINT PROJECT NO. 2017.01502

JULY 26, 2022

TOWN OF ROCKVILLE  
103 W. HIGH STREET  
ROCKVILLE, IN 47872

PREPARED BY:

AMERICAN STRUCTUREPOINT, INC.  
116 E. BERRY STREET, SUITE 1515  
FORT WAYNE, IN 46802

This Addendum forms part of the Contract Documents and modifies the original Bidding Documents as noted below. Acknowledge receipt of the Addendum in the space provided in the Bid Form. Failure to do so may subject Bidder to disqualification.

### **REVISIONS TO PROJECT MANUAL:**

1. No revisions to project manual.

### **CLARIFICATIONS/QUESTIONS AND ANSWERS:**

1. **Question:** Ductile Iron Pipe – Can galvanized grooved pipe be used in lieu of ductile iron pipe at the pump station(s)  
**Answer:** Yes.

### **OTHER:**

1. The sign-in sheet for the pre-bid meeting which was held July 19, 2022 is included with this addendum.
2. Acknowledgement of Addendum

END OF ADDENDUM NO. 1



# ADDENDUM NO. 1

Town of Rockville  
US 41 Lift Station and Sewer Replacement Project

Number of Pages (Including this page): 2

July 26, 2022

**NOTICE TO BIDDERS – IT IS MANDATORY THAT, UPON RECEIPT OF THIS ADDENDUM, YOU 1) SIGN, 2) DATE, 3) WRITE IN YOUR COMPANY NAME, AND 4) RETURN THIS SHEET TO BRYAN HOOD OF AMERICAN STRUCTUREPOINT, BHOOD@STRUCTUREPOINT.COM – THANK YOU.**

**IF YOU HAVE ANY QUESTIONS CONCERNING THIS ADDENDUM, PLEASE CALL BRYAN HOOD @ (260) 417-6312.**

1. Please sign below to acknowledge receipt of this addendum.  _____	2. Please insert date of receipt.  Date: _____	3. Please insert your company name  _____	4. Please return to Bryan Hood. bhood@structurepoint.com
--	--	---	---

This addendum is being issued as a supplement to the specifications and drawings and shall be considered an integral part of the same. This addendum will become part of the contract documents.